

CHAPTER 5

ELECTRICAL POWER SUPPLIES

5.1 INSTALLATION

- 5.1.1 The installation, control and distribution of wiring of electrical equipment in buildings shall be in accordance with SS CP 5 Code of Practice for Wiring of Electrical Equipment of Buildings and SS CP 16 Code of Practice for Earthing.

5.2 PRIMARY AND SECONDARY SUPPLIES

- 5.2.1 Where any of the following installations is required by this Code or other Codes/Regulations, its primary and secondary source of power supplies shall comply with the corresponding Code of Practice stated therein: Primary and secondary supplies
- (a) Where electrical passenger or goods lift is required, its electrical installations, inclusive of battery and other form of secondary power supply, shall comply with SS CP 2 Code of Practice for Installation, Operation and Maintenance of Electric Passenger and Goods Lifts. Where the provision of fire lift is required by this Code, installation of the primary and secondary supplies shall also comply with the above mentioned Code of Practice.
 - (b) Where electrical fire alarm system is required, its primary power supply as well as type and capacity of battery shall comply with SS CP 10 Code of Practice for the Installation and Servicing of Electrical Fire Alarm Systems.
 - (c) Where exit or emergency lighting system is required, its electrical wiring, type and capacity of battery or other form of secondary power supply shall comply with SS CP 19 Code of Practice for the Installation and Maintenance of Emergency Evacuation Lighting and Power Supply Systems in Buildings.
 - (d) Where an emergency voice communication system is required, its electrical wiring shall be fire rated or otherwise fire protected in accordance with SS CP 25 Code of Practice for Emergency Voice Communication System in Buildings. Appropriate type and capacity of secondary source of supply shall also be provided accordingly.
 - (e) Where a wet rising main system is required, the relevant electrical supply shall be installed in accordance with SS CP 29 Code of Practice for Fire Hydrant Systems and Hose Reels. A secondary source of power supply with capacity stipulated in CP 29 shall be provided for the wet rising main pumps.

	(f)	Installation of electrical supply for sprinkler system shall comply with SS CP 52 Code of Practice for Automatic Fire Sprinkler System. Capacity of secondary source of supply, where required, shall satisfy the operation requirements under the respective hazard category.	
	(g)	Mechanical ventilation where required for the following rooms or spaces shall be provided with secondary source of supply in accordance with SS CP 13 Code of Practice for Mechanical Ventilation and Air-conditioning in Buildings:	Secondary source of supply
		(i) exit staircases and exit passageways;	
		(ii) smoke-stop and fire fighting lobbies;	
		(iii) areas of refuge within the same building;	
		(iv) basement car parks;	
		(v) fire command centres;	
		(vi) flammable liquid/gas storage rooms;	
		(vii) emergency power generator room, and engine driven fire pump room;	
		(viii) carpark smoke purging system;	
		(ix) powered smoke control systems;	
		(x) any other fire precautionary measure.	
	(h)	Where mechanical ventilation is installed to provide air for the operation of the following equipment, secondary source of supply shall be provided:	
		(i) emergency generator;	
		(ii) engine driven fire pump.	
	(i)	Power supply cables for equipment that is required to operate during a fire emergency shall be of fire resistant type. The fire resistant cables shall comply with SS 299.	Cable installation
5.2.2		The following systems shall be provided with secondary source of supply:	
	(a)	Atrium smoke control system, including associated AHUs forming part of the system;	
	(b)	All smoke control systems where required by this Code.	
5.2.3		Where emergency generators are provided as a secondary source of supply, they shall comply with SS CP 31 Code of Practice for Installation, Operation, Maintenance, Performance and Constructional Requirements of Mains Failure Standby Generating Systems.	Emergency generator