



**SCDF**  
The Life Saving Force

# Annual Fire Safety Engineer (FSE) Dialogue Session

Monday 12<sup>th</sup> March 2018

2:00 pm to 5:00 pm

SCDF HQ

City Campus Level 3 Lecture Room 1A



# Agenda :

2:00 pm to 5:00 pm

- PB Regulatory Systems
  - ✓ FSE Registration
  - ✓ Number of cases
- CPE Progress Update
- Admin Requirements
- Fire Engineering Technical Requirements Update
  - ✓ Mark-up (Good, Bad, Ugly)
- AOB
- QnA



# Performance-Based Regulatory System



**SCDF**  
The Life Saving Force



# FSE registration

| 2004 | 2005 | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 |
|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| 40   | 11   | 5    | 7    | 8    | 7    | 3    | 0    | 5    | 2    | 1    | 3    | 0    | 0    |

✓ Current FSEs (“Practising” & “Restriction of Practice”) - 77



**Our Ref:** CD/FSSD/12/02/03/01

**Date** : 06 Nov 2017

Registrar, Board of Architects  
Registrar, Professional Engineers Board  
President, Singapore Institute of Architects  
President, Institution of Engineers, Singapore  
President, Association of Consulting Engineers, Singapore


Dear Sir/Mdm

## INVITATION FOR REGISTRATION AS FIRE SAFETY ENGINEER (FSE)

The SCDF has commenced its 14th FSE registration exercise and invites application for registration as FSE. The closing date for this application is on 31 Jan 2018.




# Number of PB cases



# Number of PB-WVR cases

| Year | WVR cases |
|------|-----------|
| 2013 | 40        |
| 2014 | 30        |
| 2015 | 45        |
| 2016 | 80        |
| 2017 | 160       |



# Number of PB cases

Upward trend.

## REMINDER :

- We are not here to check your reports for you.
- FSE must check all reports before submission.



# Continuing Professional Education Programme (updates)



# List of approved courses (Sep 2017 onwards)

[www.scdf.gov.sg](http://www.scdf.gov.sg)

- >> Fire Safety
- >> Fire Safety Approval
- >> Performance-Based Approach to Fire Safety Design

| S/NO | Approved Course  | Date                               | CPE Hrs |
|------|--|------------------------------------|---------|
| 1    | VIC Building Materials Compliance Seminar  | 4-Sep-17                           | 1       |
| 2    | AS 1670.1 & 1670.4 Technical Solutions Workshop  | 26-Sep-17                          | 2       |
| 3    | AS 2118.1:2017 Seminar (Any one day, 19 Sep, 21 Sep, 22 Sep, 2 Oct, 3 Oct, 5 Oct)  | Sep/Oct 2017                       | 3       |
| 4    | Combustible Cladding Forum   | 4-Oct-17                           | 2       |
| 5    | 2017 IFE Australia Conference  | 5 to 6 Oct 2017                    | 12      |
| 6    | Structural Steel Fire Design - Next Generation   | 9, 10, 11, 12 Oct 2017 (Any 1 day) | 2       |
| 7    | SFPE North America Conference & Expo   | 10-11 Oct 2017                     | 10      |
| 8    | SFPE North America Conference & Expo (Post conference course - Application of Fire Risk Assessment)  | 12-13 Oct 2017                     | 14      |
| 9    | SFPE North America Conference & Expo (Post conference course - Engineering Human Response In Fire or Engineering Analysis of Building Fires) | 12-13 Oct 2017                     | 14      |
| 10   | The AS5113 Façade Test Expo  | 26-Oct-17                          | 3       |
| 11   | Seminar on Best Practices on Design and Testing of Fire water Supply and Suppression Related to the Singapore Safety Case regulations        | 27-Oct-17                          | 3       |
| 12   | Advanced FDS and Smokeview Seminar   | 6 to 9 Nov 2017                    | 26      |
| 13   | FISAC workshop   | 15-Nov-17                          | 9       |
| 14   | FISAC conference   | 16 to 17 Nov 2017                  | 18      |
| 15   | Innovative Fire Protection   | 6-Dec-17                           | 1       |
| 16   | Victorian Cladding Taskforce   | 11-Dec-17                          | 1       |
| 17   | Introductory STEPS Training Course   | 24 to 25 Jan 2018                  | 13      |
| 18   | PATHFINDER workshop  | 19 to 20 Mar 2018                  | 14      |
| 19   | PYROSIM workshop   | 22 to 23 Mar 2018                  | 14      |
| 20   | International Fire Conference & Exhibition Malaysia  | 27 to 29 Mar 2018                  | 15      |

Online courses (Max 5 CPE hrs per training cycle)


| Course Name   | CPE hrs |
|---|---------|
| SFPE On-Demand Learning ( <a href="http://www.sfpe.org/?page=OnDemandLearning">http://www.sfpe.org/?page=OnDemandLearning</a> )                       | 4       |
| Human Behaviour in Fire   | 2.5     |
| Introduction for Fire Risk Assessment   | 4       |
| Principles of Fire Protection Engineering   |         |
| Jensen Hughes Academy courses ( <a href="https://www.jensenhughesacademy.com/core/index.php">https://www.jensenhughesacademy.com/core/index.php</a> ) | CPE hrs |
| Smoke control bundle  | 2       |

|    |   |                   |    |
|----|---|-------------------|----|
| 17 | Introductory STEPS Training Course                  | 24 to 25 Jan 2018 | 13 |
| 18 | PATHFINDER workshop                                 | 19 to 20 Mar 2018 | 14 |
| 19 | PYROSIM workshop                                    | 22 to 23 Mar 2018 | 14 |
| 20 | International Fire Conference & Exhibition Malaysia | 27 to 29 Mar 2018 | 15 |




# CPE Programme

- Attain minimum 48 CPE hours for every 2 year-cycle. Cycle starts on:
  - 1 Sep 2013 (for FSEs registered before 1 Sep 2013)
  - FSE registration date (for FSEs registered after 1 Sep 2013)
- Different FSEs may have different CPE training cycle start/end dates
- FSE's responsibility to track and monitor own CPE training records
  - ✓ Development of CPE portal still on-going



## Carry over of CPE hours (Example)



- Allow extra CPE hours (up to 24 additional CPE hrs in the immediate previous cycle) to be carried forward to the NEXT training cycle only



# Failure to meet CPE requirements


| Registration Number | Registration Date         | Full Name | Correspondence Address / E-mail Address                                | Contact Number (Office / Home / HP) | Status*   |
|---------------------|---------------------------|-----------|--|-------------------------------------|---|
| 025                 | 1 <sup>st</sup> July 2004 |           |  | )                                   | Practising  |
| 026                 | -                         |           | E-mail: <a href="mailto:105800@smgntc.com.sg">105800@smgntc.com.sg</a> |                                     | Not practising                                    |
| 027                 | 1 <sup>st</sup> July 2004 |           |  |                                     | Practising  |
| 028                 | -                         |           |  |                                     | Not practising                                    |
| 029                 | 1 <sup>st</sup> July 2004 |           |  |                                     | Restriction of Practice (From 1 Sep 2017 onwards) |
| 030                 | -                         |           |  |                                     | Not practising                                    |
| 031                 | 1 <sup>st</sup> July 2004 |           |  |                                     | Practising  |
| 032                 | 1 <sup>st</sup> July 2004 |           |  |                                     | Restriction of Practice (From 1 Sep 2017 onwards) |

Practising status listed as “Restriction of Practice” instead of “Practising” in FSE register

- Unable to submit PB plans & reports
- Existing submissions will not be processed further
- Allow reinstatement once they fulfill 48 CPE hours within a 2 year period (see example in next slide)
  - From the point of reinstatement to the end of the FSE’s cycle, need to attain pro-rated CPE hours to maintain status.
  - FSE to submit reinstatement declaration



# Example







[www.scdf.gov.sg](http://www.scdf.gov.sg)

>> Fire Safety

>> Fire Safety Approval

>> Performance-Based Approach to Fire Safety Design

The performance-based regulatory system was officially launched on 1 July 2004.

- › Registration for Fire Safety Engineers
- › List of Projects involving Performance-Based Fire Safety Design
- › List of approved CPE courses
- › Fire Safety Engineering (FSE) Dialogue Session
- › Register of Fire Safety Engineers
- › Performance-Based Plan Approval Process
- › Roles & Responsibilities
- › Performance-Based Provisions
- › Performance-Based Provisions Code Structure
- › Frequently Asked Questions
- › Circulars on Performance-Based Fire Safety Issues

The screenshot shows the SCDF website's navigation menu with options: Home, General, Fire Safety, Civil Defence Shelter, Community & Volunteers, CD NSmen & NSF, Career, E-Services, and Useful Links. The main banner features the text "MISSION To protect and save lives and property for a safe and secure Singapore" with an image of firefighters. Below the banner is a sidebar menu with items: Building Materials, Waiver Application, Minor Addition/Alteration Works, Plan Approval, Performance-Based Approach to Fire Safety Design (highlighted in orange), and Consultations. The main content area is titled "FIRE SAFETY Performance-Based Approach to Fire Safety Design" and includes an "Introduction" section. The introduction text states: "The performance-based approach to fire safety design relies on the use of fire engineering principles, calculations and/or appropriate software modelling tools to satisfy the intentions of the Code of Practice for Fire Precautions in Buildings 2013 (Fire Code). This new approach provides alternative means of meeting the intentions of the Fire Code. Building practitioners will have the added flexibility in the application of fire safety for their buildings by having a choice of using the performance-based approach, the prescriptive approach or a combination of both." It also notes that the performance-based approach is unique in that its provisions spell out the intent of the code qualitatively but the means of achieving the desired intent of the code is open to the building practitioner. The page concludes with the launch date and a list of navigation links.

Home General Fire Safety Civil Defence Shelter Community & Volunteers CD NSmen & NSF Career E-Services Useful Links

MISSION  
To protect and save lives and property  
for a safe and secure Singapore

Font A+ A- | Share + | Print Friendly

Building Materials  
Waiver Application  
Minor Addition/Alteration Works  
Plan Approval  
**Performance-Based Approach to Fire Safety Design**  
Consultations

## FIRE SAFETY

### Performance-Based Approach to Fire Safety Design

#### Introduction

The performance-based approach to fire safety design relies on the use of fire engineering principles, calculations and/or appropriate software modelling tools to satisfy the intentions of the Code of Practice for Fire Precautions in Buildings 2013 (Fire Code). This new approach provides alternative means of meeting the intentions of the Fire Code. Building practitioners will have the added flexibility in the application of fire safety for their buildings by having a choice of using the performance-based approach, the prescriptive approach or a combination of both.

The performance-based approach is unique in that its provisions spell out the intent of the code qualitatively but the means of achieving the desired intent of the code is open to the building practitioner. The building practitioner will need to substantiate that the proposed solution fully meets the intent of the Fire Code using established fire safety engineering methodology.

The performance-based regulatory system was officially launched on 1 July 2004.

- › Registration for Fire Safety Engineers
- › List of Projects involving Performance-Based Fire Safety Design
- › List of approved CPE courses
- › Fire Safety Engineering (FSE) Dialogue Session
- › Register of Fire Safety Engineers
- › Performance-Based Plan Approval Process
- › Roles & Responsibilities
- › Performance-Based Provisions
- › Performance-Based Provisions Code Structure
- › Frequently Asked Questions
- › Circulars on Performance-Based Fire Safety Issues

- Searchable format
- Postal Code added


## List of Performance-Based Fire Engineering Projects

The performance-based regulatory system was officially launched on 1 July 2004.

- ▶ Registration for Fire Safety Engineers
- ▶ List of Projects involving Performance-Based Fire Safety Design
- ▶ List of approved CPE courses
- ▶ Fire Safety Engineering (FSE) Dialogue Session
- ▶ Register of Fire Safety Engineers
- ▶ Performance-Based Plan Approval Process
- ▶ Roles & Responsibilities
- ▶ Performance-Based Provisions
- ▶ Performance-Based Provisions Code Structure
- ▶ Frequently Asked Questions
- ▶ Circulars on Performance-Based Fire Safety Issues

| Reference number | Registration date | Title   | Postal Code |
|------------------|-------------------|---|-------------|
| FEDB/001061/04   | 15/7/2004         | APPLICATION FOR IN-PRINCIPLE AGREEMENT OF FIRE SAFETY ENGINEERING BRIEF - FOR THE FIRE ENGINEERING ANALYSIS ON THE USE OF ALPOLIC/FR 30% PERFORATION PANELS AT THE BOTTOM OF THE ROOF TRUSS (BELOW THE CEILING) IN TERMINAL 3S DEPARTURE HALL   | 819663      |
| FEDB/001100/04   | 17/11/2004        | PROPOSED ERECTION OF SINGLE STOREY EXHIBITION HALL HALL 7 TO 10 FOR SINGAPORE EXPO EXPANSION ON LOTS 09788T PT(SL) 07360L PT(SL) 09566A PT(SL)07361C PT(SL) 98328L(SL)MK 27 AT EXPO DRIVE/UPPER CHANGI ROAD EAST/CHANGI SOUTH AVENUE 1  |             |
| FEDB/001120/05   | 7/11/2005         | PROPOSED ERECTION OF PART SINGLE STOREY/PART 2-STOREY, SOUTHERN TRABSPORT TRANSIT COMPLEX WITH BASEMENT CAOMPRISING OF CARPARKS MONORAIL STATION AND DEPOT BUILDING ON LOT 254PT(SL), 451PT(SL), 497PT(SL), 589PT(SL) MK 34 PALAWAN BEACH, SENTOSA (SOUTHERN ISLANDS PLANNING AREA)   |             |
| FEDB/001160/05   | 24/11/2005        | PROPOSED ADDITIONS & ALTERATIONS TO BLOCK A, B, C, D AND CANOPY OVER THE INTERNAL STREETS ON LOT 152 155 158 159 161 AND STATE LAND LOTS 275PT 273PT 273PT[SLRD] 274PT 276PT AND 277PT TS 09 AT CLARKE QUAY (CONSERVATION AREA) RIVER VALLEY ROAD SINGAPORE   |             |
| FEDB/001200/05   | 21/2/2005         | PROPOSED EXTENSION WITH ALTERATIONS AND ADDITIONS TO EXISTING SINGLE-STOREY GROCERY WAREHOUSE WITH 3-STOREY ANCILLARY OFFICE ON LOT 2292K MK 7 AT NO. 37 JOO KOON CIRCLE (JURONG INDUSTRIAL ESTATE - PIONEER PLANNING DGP)  | 629062      |
| FEDB/001220/05   | 31/3/2005         | PROPOSED CARPARK VENTILATION SYSTEM TO THE PROPOSED CONDOMINIUM DEVELOPMENT COMPRISING 7 BLOCKS OF 10-STOREY APARTMENTS (TOTAL: 318 UNITS) WITH BASEMENT CARPARK, 3 SWIMMING POOLS AND ANCILLARY FACILITIES ON LOTS 2070, 2072PT MK 16 AT DUNEARN ROAD (BUKIT TIMAH PLANNING AREA)  |             |
| FEDB/001260/05   | 22/4/2005         | PROPOSED CARPARK MECHANICAL VENTILATION SYSTEM (USING DIRECT AXIAL FANS) TO PROPOSED ERECTION OF 15 BLOCKS OF 6-STOREY W/ATTIC CONDOMINIUM HOUSING DEVELOPMENT (TOTAL 200 UNITS) WITH BASEMENT CARPARK AND SWIMMING ON LOT 1392M MK 34 AT OCEAN DRIVE   |             |
| FEDB/001280/05   | 10/6/2005         | PROPOSED ERECTION OF A 5-STOREY SINGLE-USER WAREHOUSE WITH A 9-STOREY ANCILLARY OFFICE ANNEXE ON LOT 7994X PT (JTC PLOT A0524401) MK 5 AT PENJURU LANE  | 609206      |
| FEDB/001300/05   | 24/6/2005         | PROPOSED MINI JET FANS DUCTLESS CARPARK VENTILATION SYSTEM TO PROPOSED RESIDENTIAL DEVELOPMENT COMPRISING THE ERECTION OF 1 BLOCK OF 7 STOREY APARTMENT AT UPPER BUKIT TIMAH ROAD   | 678185      |
| FEDB/001301/05   | 24/6/2005         | PROPOSED MINI JET FANS DUCTLESS CARPARK MECHANICAL VENTILATION SYSTEM TO PROPOSED MIXED COMMERCIAL DEVELOPMENT COMPRISING 1 BLOCK OF 25-STOREY OFFICE TOWER WITH ELEVATED CAR PARKS 1 BLOCK OF 12-STOREY SOHO TOWER 1 BLOCK OF 8-STOREY SOHO TOWER WITH CIVIC & COMMUNITY INSTITUTION ON 3RD & 4TH STOREY AND A 4-STOREY RETAIL CUM F & B PODIUM WITH 1 BASEMENT ON URA PARCEL 594 TS 07 AT EU TONG SENG STREET/TEW CHEW STREET | 059817      |
| FEDB/001320/05   | 24/6/2005         | PROPOSED MINI JET FANS DUCTLESS CARPARK MECHANICAL VENTILATION SYSTEM TO PROPOSED AMENDMENT TO APPROVE CONDOMINIUM HOUSING DEVELOPMENT COMPRISING 5 BLOCK OF 8 STOREY APARTMENTS(TOTAL 295 UNITS) WITH COMMON BASEMENT AND COMMUNAL FACILITIES AT MOUNT EMILY ROAD  | 228406      |
| FEDB/001340/05   | 8/9/2005          | PROPOSED DUCTLESS JET FANS SYSTEM FOR MECHANICAL VENTILATION & SMOKE PURGING FOR CARPARK TO PROPOSED CONDOMINIUM HOUSING DEVELOPMENT COMPRISING 12 BLOCKS OF 17-STOREY RESIDENTIAL BUILDINGS WITH BASEMENT CARPARK, TENNIS COURTS, SWIMMING POOL, CLUBHOUSE AND COMMUNAL FACILITIES ON LOT 8988K, MUKIM 22 (URA LAND PARCEL) AT KOVAN ROAD/FLOWER ROAD (HOUGANG PLANNING AREA)  |             |
| FEDB/001380/05   | 3/10/2005         | PROPOSED ERECTION OF A 8-STOREY SINGLE-USER LIGHT INDUSTRIAL DEVELOPMENT (LOGISTICS HUB) ON LOT 4201N PT (JTC PLOT A1997000) MK 31 AT ALPS AVENUE   |             |
| FEDB/001390/05   | 24/10/2005        | PROPOSED ERECTION OF A 4-STOREY SINGLE-USER LIGHT INDUSTRIAL DEVELOPMENT (LOGISTICS   |             |





Dear Fire Safety Engineers (FSEs, in bcc)

This is to inform you that the events below will be considered as part of the approved courses for FSE Continuing Professional Education (CPE) programme. You may refer to the attachments for more information and registration details.

| S/N | Event               | Date              | Venue              | Event details   | CPE hours |
|-----|---------------------|-------------------|--------------------|---|-----------|
| 1   | PATHFINDER workshop | 19 to 20 Mar 2018 | 460 Alexandra Road |  20180319-20 Py... | 14        |
| 2   | PYROSIM workshop    | 22 to 23 Mar 2018 |                    |   | 14        |

2 For FSEs who are attending the event, you are required to show documentary proof of participation from the event organiser and forward it to me within 1 month from the end of the event.

3 Just a gentle reminder to FSEs that you will need to submit a declaration at the end of your CPE training cycle to indicate all the approved CPE courses you have attended for your CPE training cycle. A template of the declaration form is attached. If you are unsure of the period of your CPE training cycle, you may contact me for more information.



CPE declaration  
template - dat...

4 For Fire Safety Engineers whose practising status is currently under "Restriction of Practice", if you have attained the reinstatement criteria (i.e. achieve 48 CPE hours within a continuous 2-year period during the restriction), you may apply to reinstate your status to "Practising" by submitting the below CPE declaration form to me. You may refer to your practising status in the FSE Register (Go to [www.scdf.gov.sg](http://www.scdf.gov.sg). Under Fire Safety/Fire Safety Approval, Click on Performance-Based Approach to Fire Safety Design).



CPE declaration  
template (for...

5 Thank you.

**LTC Tong Hong Haey**  
Senior Consultant (Performance-Based Plans)  
Fire Safety & Shelter Department  
Singapore Civil Defence Force  
DID: (65) 6848 1448

# Fire Engineering Technical Requirements Update



**SCDF**  
The Life Saving Force



# FSEs, please check your submission.

1. Accuracy (Numerical or otherwise).
2. Spelling.
3. Diagrams and references
4. Correct case reference numbers
5. Etc, etc...



# Soot Yield


1. Adopt 0.1 (SFEG) or
2. Justify based on sprinkler design
  - a) Hazard category
  - b) Highest value
  - c) Add 20% safety factor
  - d) Discuss in separate section in FER



# Acceptance Criteria for residential corridors.

180 seconds after door opens, at the height of  $Z = 2\text{m}$ :


1. Visibility for the whole corridor must **exceed 10m** &
2. Temperature for the whole corridor must be **less than 60°C**.



# Acceptance Criteria for residential corridors.

180 seconds after door opens, at the height of  $Z = 2\text{m}$ :

1. Visibility for the whole corridor must **exceed 10m** &
2. Temperature for the whole corridor must be **less than 60°C**.



# Resi WVR Applications :

Conditional Acceptance if WVR (with FER) is approved :

*CONDITION: To install Home Fire Alarm Devices (**HFAD**) for all homes in this block. HFAD specifications and installation requirements shall follow SCDF circular dated 16 Nov 2017.*



# ASET

1. Taken when first queuing location fails tenability criteria. Could be at :
  - a) Main exit door
  - b) Exit staircase door
  - c) SSL/FFL door
  - d) etc





# ASET

1. Taken when first queuing location fails tenability criteria. Could be at :
  - a) Main exit door
  - b) Exit staircase door
  - c) SSL/FFL door
  - d) etc
2. Mark out these egress provisions clearly in CFD results.
3. Show ASET slice in FER.
4. Show closer time steps slightly before/after ASET timing so that SCDF can agree/disagree with ASET timing adopted.






# **PB Administrative Requirements (Submission for waiver with fire engineering study)**



One PB clause, three issues (3 blocks):

- PB 1 – Blk A
- PB 2 – Blk B
- PB 3 – Blk C



Clause 2.2.13(b)(i)



## Clause 2.2.13(b)(i)

One clause, Three issues:

- PB 1 – Blk A
- PB 2 – Blk B
- PB 3 – Blk C

WVR/00001/18 **FER**

- PB 1

WVR/00002/18 **FER**

- PB2

WVR/00003/18 **FER**

- PB 3

**Will be REJECTED**

WVR/00001/18 **FER**

- PB 1
- PB 2
- PB 3

WVR/00001/18 **FER**

- PB for Blks A, B & C

Clause 2.2.13(b)(i)

**Will be REJECTED**

## Clause 2.2.13(b)(i)

One clause, Three issues:

- PB 1 – Blk A
- PB 2 – Blk B
- PB 3 – Blk C

WVR/00001/18

FER

- PB 1
- PB 2
- PB 3




**Every block/issue requires waiver application, regardless of whether blocks are identical or not. This is because:**

1. Each block should have their own identity
2. There could be difference in discharge conditions
3. There could be other factors that affect the study (different airwell size)
4. There must be a means to approve and reject some identical blocks (if there is a need to)
5. Sometimes, it may appear identical to FSEs, but it may not appear identical to SCDF



Multiple blocks  
(regardless of  
whether blocks are  
identical or not)  
with multiple PB  
issues



WVR/00001/18 **FER**

- PB A1
- PB B1
- PB B2
- PB C1
- PB C2



WVR/00001/18 **FER**

- PB A1, B1, B2, C1, C2



**Will be REJECTED**



WVR/00001/18 **FER**

- PB A1
- PB B1
- PB B2
- PB C1
- PB C2



WVR/00001/18

**FER**

- PB A1

WVR/00002/18

**FER**

- PB B1, PB B2


WVR/00003/18

**FER**

- PB C1

WVR/00004/18

- PB C2



**Will be REJECTED**




WVR/00001/18 **FER**

- PB A1
- PB B1
- PB B2
- PB C1
- PB C2



WVR/00001/18 **FER**

- PB A1
- PB B1, PB B2
- PB C1, PB C2



Deviations are not to be submitted solely by “per block”.  
Check number of deviations in each block before submission.

**Will be REJECTED**

# Building with multiple fire safety non-compliances

*Prescriptive 2*

**Prescriptive 1**

**Prescriptive 3**

**PB 4**

**PB 1**

**PB 3**

**PB 2**

**Prescriptive 4**

**Prescriptive 5**



# Building with multiple fire safety non-compliances

WVR/00001/18

FER

Will be REJECTED

- PB 1
- PB 2
- PB 3
- PB 4
- Prescriptive 1
- Prescriptive 2
- Prescriptive 3
- Prescriptive 4
- Prescriptive 5



# Building with multiple fire safety non-compliances

WVR/00001/18 **FER**

- PB 1

WVR/00002/18 **FER**

- PB 2

WVR/00003/18 **FER**

- PB 3

WVR/00004/18 **FER**

- PB 4

**Will be REJECTED**

WVR/00005/18

- **Prescriptive 1**

WVR/00006/18

- **Prescriptive 2**

WVR/00007/18

- **Prescriptive 3**

WVR/00008/18

- **Prescriptive 4**

WVR/00009/18

- **Prescriptive 5**



# Building with multiple fire safety non-compliances

WVR/00001/18 **FER**

- PB 1
- PB 2
- PB 3
- PB 4



WVR/00002/18

- Prescriptive 1
- Prescriptive 2
- Prescriptive 3
- Prescriptive 4
- Prescriptive 5



# **PB Administrative Requirements (Clarity of submission for WVR)**



# Building/Development with multiple PB issues/areas

- All deviations to be clearly written. Which clause for which block/floor/area. Do not refer to Appendices.

**Else REJECT**



- PJT201803328
- WAIVER
- WVR-00513-18
  - PROJECT-PROFILE(02-Mar-2018 20-
  - SUBMISSION(02-Mar-2018 20-43-19)
  - FSSD-0-WVFSR02.XFD(02-Mar-2018
  - ES20180302-91839(02-Mar-2018 20-
  - FSSD-0-WVFSR02(02-Mar-2018 20-4
  - ES\_SUBMISSION(02-Mar-2018 20-43
  - 1353\_Fire Engineer Report.pdf(02-Ma
  - 1353\_Fire Engineer Report(02-Mar-20
  - 1353\_Architectural Drawings.pdf(02-lv
  - 1353\_Architectural Drawings(02-Mar-
  - 1353\_Appendix 1(02-Mar-2018 20-42-
  - 1353 Cover Letter(02-Mar-2018 20-42
  - 1353 Cover Letter.pdf(02-Mar-2018 20
  - 1353\_Appendix 1.pdf(02-Mar-2018 20
  - WVR\_ACK\_EXT(02-Mar-2018 20-42-

Workflow Info

Waiver Issue Details

SAVE

Meeting date

Real Waiver

Fire Code

Clause no \*

Please specify if others

Committee Decision

Chairperson

Waiver Type

QP Present

Description (4000 Characters max)

Please refer to Appendix 1.

This line appears in the WVR decision letter

Provision (4000 Characters max)

Please refer to Appendix 1.

Supporting Reason (4000 Characters max)

Please refer to Appendix 1.

Condition(s)/ Reason (s)/ Others (4000 Characters max)

Remarks (500 Characters max)



| Status        | Action |
|---------------|--------|
| Please Select |        |

| Date     | Document Name   |
|----------|-----------------|
| 09:14 AM | WVR_ACK_EXT.pdf |
| 15:57 PM | WVR_ACK_EXT.pdf |
| 22:55 PM | WVR_ACK_EXT.pdf |

# Building/Development with multiple PB issues/areas

- All deviations to be clearly written. Which clause for which block/floor/area. Do not refer to Appendices. **Else REJECT**
- Be mindful not to simply quote the clause. [Eg : 2.2.13 (b)(iii)] but highlight the deviation.

*Clause 2.2.13 (b)(iii) : permanently fixed ventilation openings of area not less than **15 per cent** of the floor area of the lobby and located not more than **9m** from any part of the lobby, opening to an open air well which is open vertically to the sky for its full height. The air-well size shall be in accordance with Cl.2.2.13(a)(iii) except for building not more than 4-storey, in which the air-well shall have a horizontal plan **area** of not less than 10m<sup>2</sup> or 0.1m<sup>2</sup> for each 300mm of height of the building, whichever is the greater. The minimum width of such air-well space shall not be less than **3000mm**. The enclosure walls to the air well shall have a minimum **fire resistance of 1 hour** and have no openings other than ventilation openings for the smoke-stop lobby, exit staircase and toilets, or*



# Building/Development with multiple PB issues/areas

- Deviations indicated in WVR submissions (CORENET or manual) must match/correspond exactly to that stated in fire engineering reports (**No additional clauses, no shortage of clauses**). **Else REJECTED**
- Advise your QP well. Every deviation for every block needs a WVR application.

*Eg : 5 identical blocks with 2 deviations each requires 10 WVR applications.*



# Building/Development with multiple PB issues/areas

- ***Rejection : Submission is not in compliance to guidelines given to FSE on 12/3/18.***



# **PB Administrative Requirements (Clearing up of current WVRs)**



**SCDF**  
The Life Saving Force



WAIVER  
WVR-00779-17

W\_Decision(22-May-2017 15-31-0

20170522 WVR 00779 17

20170522 WVR 00779 17

20170406 WVR 00779 17

20170406 WVR 00779 17

20170405 WVR 00779 17

20170330 WVR 00779 17

20170330 WVR 00779 17

20170330 WVR 00779 17

fds-FS6\_BLOCK9\_L2-15(30-Mar-2

fds-FS5-BLOCK9\_L1(30-Mar-2017

fds-FS4\_BLOCK8\_L1(30-Mar-201

fds-FS2\_BLOCK4\_L1(30-Mar-201

fds-FS3\_BLOCK6\_L1(30-Mar-201

fds-FS1\_BLOCK3\_L1(30-Mar-201

20170327 WVR 00779 17 - Alps(2

| Summary Info | Applicant details   | Building details | Qp Details | Waiver Issue | Payment | Case folder | Related c |
|--------------|---|------------------|------------|--------------|---------|-------------|-----------|
| Issue No     | Description   |                  |            |              |         |             |           |
| 1            | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky having a travel distance not more than 10m for Blocks 1, 2, 4 and 5.    |                  |            |              |         |             |           |
| 2            | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky having a travel distance not more than 10m for Block 3.                 |                  |            |              |         |             |           |
| 3            | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky having a travel distance not more than 10m for Block 6.                 |                  |            |              |         |             |           |
| 4            | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky having a travel distance not more than 10m for Block 7.                 |                  |            |              |         |             |           |
| 5            | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky having a travel distance not more than 10m for Block 8.                 |                  |            |              |         |             |           |
| 6            | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky at having a travel distance not more than 10m for Block 9 SS9 and SS10. |                  |            |              |         |             |           |
| 7            | To waive Fire Code Cl 2.2.13 (b)(iii), to permit fire fighting lobby natural ventilation in one direction exceeding 9m for Block 9.   |                  |            |              |         |             |           |

One WVR Ref No.

1 FER, not 7

7 issues

Separate issues for same block (Block 9)



WAIVER

WVR-00779-17

- W\_Decision(22-May-2017 15-31-0
- 20170522 WVR 00779 17
- 20170522 WVR 00779 17
- 20170406 WVR 00779 17
- 20170406 WVR 00779 17
- 20170405 WVR 00779 17
- 20170330 WVR 00779 17
- 20170330 WVR 00779 17
- 20170330 WVR 00779 17
- fds-FS6\_BLOCK9\_L2-15(30-Mar-2
- fds-FS5-BLOCK9\_L1(30-Mar-2017
- fds-FS4\_BLOCK8\_L1(30-Mar-201
- fds-FS2\_BLOCK4\_L1(30-Mar-201
- fds-FS3\_BLOCK6\_L1(30-Mar-201
- fds-FS1\_BLOCK3\_L1(30-Mar-201
- 20170327 WVR 00779 17 - Alps(2

| Summary Info | Applicant details   | Building details | Qp Details | Waiver Issue | Payment | Case folder | Related o |
|--------------|---|------------------|------------|--------------|---------|-------------|-----------|
| Issue No     | Description   |                  |            |              |         |             |           |
| 1            | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky having a travel distance not more than 10m for Blocks 1, 2, 4 and 5.    |                  |            |              |         |             |           |
| 2            | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky having a travel distance not more than 10m for Block 3.                 |                  |            |              |         |             |           |
| 3            | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky having a travel distance not more than 10m for Block 6.                 |                  |            |              |         |             |           |
| 4            | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky having a travel distance not more than 10m for Block 7.                 |                  |            |              |         |             |           |
| 5            | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky having a travel distance not more than 10m for Block 8.                 |                  |            |              |         |             |           |
| 6            | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky at having a travel distance not more than 10m for Block 9 SS9 and SS10. |                  |            |              |         |             |           |
| 7            | To waive Fire Code Cl 2.2.13 (b)(iii), to permit fire fighting lobby natural ventilation in one direction exceeding 9m for Block 9.   |                  |            |              |         |             |           |

**Blocks 1, 2, 4 & 5 should be separate waiver submissions.**

**There should be 10 waiver applications, not 7.**



WAIVER

WVR-00779-17

- W\_Decision(22-May-2017 15-31-0
- 20170522 WVR 00779 17
- 20170522 WVR 00779 17
- 20170406 WVR 00779 17
- 20170406 WVR 00779 17
- 20170405 WVR 00779 17
- 20170330 WVR 00779 17
- 20170330 WVR 00779 17
- 20170330 WVR 00779 17
- fds-FS6\_BLOCK9\_L2-15(30-Mar-2
- fds-FS5-BLOCK9\_L1(30-Mar-2017
- fds-FS4\_BLOCK8\_L1(30-Mar-201
- fds-FS2\_BLOCK4\_L1(30-Mar-201
- fds-FS3\_BLOCK6\_L1(30-Mar-201
- fds-FS1\_BLOCK3\_L1(30-Mar-201
- 20170327 WVR 00779 17 - Alps(2

| Issue No | Description   |
|----------|---|
| 1        | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky having a travel distance not more than 10m for Blocks 1, 2, 4 and 5.    |
| 2        | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky having a travel distance not more than 10m for Block 3.                 |
| 3        | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky having a travel distance not more than 10m for Block 6.                 |
| 4        | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky having a travel distance not more than 10m for Block 7.                 |
| 5        | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky having a travel distance not more than 10m for Block 8.                 |
| 6        | To waive Fire Code Cl 2.3.3 (c)(i), to permit staircase discharge through the fire fighting lobby at ground level directly into safe exterior space open to sky at having a travel distance not more than 10m for Block 9 SS9 and SS10. |
| 7        | To waive Fire Code Cl 2.2.13 (b)(iii), to permit fire fighting lobby natural ventilation in one direction exceeding 9m for Block 9.   |

**Issue 1 needs to be regularised by QP.**

**Submit and generate a new WVR Ref number for the 3 outstanding issues. (Blocks 2, 4 & 5)**

**QP needs to update issue 1 in original waiver.**



# **PB Administrative Requirements (PB Presentations)**



**SCDF**  
The Life Saving Force



# What is shown during PB presentation:

- Title (Description)
- Introduce the building (Building plans)
- **Table & Drawing** of Deviations
- **Table & Drawing** of Design fire scenarios
  - ✓ **Tabulate** even for singular deviation or design fire scenario
- Mark-up drawings
- Analysis and results

**REJECTED if missing**



# What is shown during PB presentation:

- Deviations (Table)
  - ✓ Insert **extent** where applicable.
  - ✓ Highlight key **numbers**.



# What is shown during PB presentation:

- Design fire scenarios (Table)
  - ✓ Name all scenarios (FS1, BC1, SS1a,)
  - ✓ Include soot yield in a column **REJECTED if missing**
  - ✓ Remark the Sens Study (What has changed).
    - Fire size up 20%
    - Vent closed



# What is shown during PB presentation:

- Mark-up drawings – General principals
  - ✓ Large font. What is important must be large.
  - ✓ Deviations vis-a-vis design fires.
  - ✓ Height - Must be shown on all plans and spelt out in full :  
“HEIGHT”.



# What is shown during PB presentation:

- Mark-up drawings – General principals
  - ✓ Pt form/abbreviations gd (Smk res, Sprk, Elev, UF, etc)
  - ✓ Colours must make sense and have contrast
  - ✓ One zoom-in (or no zoom)
  - ✓ No legends



# Help us to help you.



**SCDF**  
The Life Saving Force



# Examples : Good

*“A good mark-up drawing speaks for itself.”*



# Examples : Good (But not all good)




**SCDF**  
The Life Saving Force



**Important info needs to  
be clearly seen and vice-  
versa.**





| <u>No.</u> | <u>Location</u>                            | <u>Part(s) of building affected by the deviation</u>   | <u>Relevant prescriptive clause in Code of Practice for Fire Precautions in Buildings 2013</u> | <u>Corresponding root and sub-objectives of proposed deviation</u> |
|------------|--|--|--|--|
| 1          | 4 <sup>th</sup> to 10 <sup>th</sup> storey | <p>To allow smoke reservoir length to exceed <u>60m</u>:</p> <ul style="list-style-type: none"> <li>• <u>Smoke zone SZ-1 (GL 4-6/G-A) length of 71m</u></li> <li>• <u>Smoke zone SZ-2 (GL 6-12/A-D) length of 69m</u></li> </ul> | <p>Clause 7.6.10 - <i>The maximum length of the smoke reservoir shall not exceed 60m.</i></p>  | <p>R7.1, R7.2, S7.1, S7.2</p>                                      |

Good : Use of colours.

Bad : Why underline everything ?



| No. | Location          | Part(s) of building affected by the deviation  | Relevant prescriptive clause in Code of Practice for Fire Precautions in Buildings 2013 | Corresponding and sub-objective proposed deviation |
|-----|-------------------|--|---|--|
| 1   | Block 1 – Level 1 | Distance from exit staircase (SS1 & ST1A) discharge point to exterior space opened to sky exceeds 10m (15.3m and 11.4m)                                      | <u>2.3.3(c)(ii)(3)</u>  | R2.1, S2.14  |
| 2   | Block 5 – Level 1 | Distance from exit staircase (SS 5) discharge point to exterior space opened to sky exceeds 10m (10.3m)  | <u>2.3.3(c)(ii)(3)</u>  | R2.1, S2.14  |
| 3   |                   | Seven (7) residential units (exceeding four (4) units) opening into the designated escape passageway at grade level into which the exit staircase discharges | <u>2.3.3(c)(ii)(4)</u>  |  |

# Proposed Fire Scenarios

Warehouse unit's non-compliances:


- Extended smoke reservoir  
(A):  $8,900\text{m}^2 > 2,000\text{m}^2$   
(L):  $139\text{m} > 60\text{m}$   
(H):  $9.625\text{m}$

2. Extended Travel Distance -  $71.3\text{m} > 60\text{m}$

Loading/Unloading Bay & Driveway non-compliances:  
(A):  $1647.5\text{m}^2$   
(L):  $71\text{m} > 60\text{m}$   
(H):  $9.625\text{m}$

S2: 10MW General goods vehicle fire

S1: 4.1MW ultra-fast t<sup>2</sup> fire  
SS1: 1MW - Reduced fire size (buoyancy study)  
SS2: 4.1MW - Blocked opening along Elevation 1








Figure 133: Key design features – Level 3




Slice VIS<sub>Soot</sub> m



**Soot visibility slice**  
@ Z = 2.0m from FFL  
@ T = 0s

Slice VIS<sub>Soot</sub> m



**Soot visibility Slice @**  
Z = 2.0m from FFL  
when door opened  
for 5s @ T = 65 s

| Time                         | Event  |
|------------------------------|--|
| 0s – 60s                     | Fire Door Closed   |
| 60s – 120s<br>(60s interval) | Smoke layer drops to<br>20% ceiling - Fire<br>Door Opens @ 60s |
| 120s<br>onwards              | Fire Door Closed   |

Floor-to-floor height = 2.975m

Elevation 3  
Opening 89.82m<sup>2</sup>  
(51.36%)

Elevation 4  
Opening 36.24m<sup>2</sup>  
(25.22%)

Elevation 2  
Opening 13.18m<sup>2</sup>  
(41.66%)

Void  
120.8m<sup>2</sup>


Void  
64.1m<sup>2</sup>

Wall  
(blue)

Area more than  
12m from  
perimeter  
opening/air-well  
(approx 406m<sup>2</sup>)

Elevation 1  
Opening 139.65m<sup>2</sup>  
(52.20%)

Perimeter  
opening  
(magenta)



# Level 1 Floor Plan

Height: 12 m

(2) Direct Dist.  
43 m > 40 m


**WAREHOUSE ZONE (MV)**

(8) Activated by ESFR  
(4) 4221 m<sup>2</sup> > 2600 m<sup>2</sup>

**LOADING BAY /  
RAMP ZONE (NV)**

(5) 4345 m<sup>2</sup> > 2000 m<sup>2</sup>

(3) Setback 7.7 m < 17 m



# Examples : Bad



**SCDF**  
The Life Saving Force



**Location affected by Performance-Based Solution**

**Corresponding Clauses**

**Design Solution and Method of Assessment**

**Acceptance Criteria**

Units at retail podiums (P1 and P2) levels 3-5 (exclude anchor tenant & departmental store). Refer to Figure 7 to Figure 9 for PBD areas.

Cl.2.2.5  
Table 2.2A  
Root Objectives: - R2.1  
Sub-objectives: - S2.1, S2.2, S2.6, S2.13

**Issues to the left please.**

To allow an increase in occupant numbers on levels 3-5, beyond the exit capacity allowed for in the prescriptive code requirement.

Based on achieving the life safety criteria for smoke and heat nominated in the approved FEDB and section 7.0 of this report, i.e.  
“PBD is deemed acceptable if the ASET/RSET results achieved a safety factor of 2 for base case design and 1.2 for sensitivity studies”



|           | <b>Locations affected by the PB Solution</b>  | <b>Relevant Prescriptive Clause</b>       | <b>Corresponding Root &amp; Sub-Objectives</b>                           | <b>Design Solution</b>   | <b>Acceptance Criteria</b>  |
|-----------|---|---|--|--|---|
| <b>a)</b> | Review the effectiveness of the natural and/or mechanical engineered smoke control system for the rail depot located at basement 1 and basement 2 and the bus depot generally located at 1 <sup>st</sup> storey to 3 <sup>rd</sup> storey above ground to | 7.6.7(a)<br>7.6.10<br>7.6.13(d)<br>7.6.16 | Root Objectives<br>- R7.1<br><br>Sub-Objectives<br>- S7.1<br>and<br>S7.2 | <p>Passive design of the underground MRT depot and Bus depot with natural replacement air and vent shafts/openings to facilitate natural or mechanical discharge of smoke in the event of fire incidents.</p> <p>The underground depot will be subdivided into several smoke zones of not more than 40,000m<sup>2</sup>, each zone will be designed with natural or mechanical smoke vents and passive natural replacement opening to facilitate discharge of smoke during fire incidents.</p> | <p>a. untenable condition as mentioned below will not arise throughout the evacuation period.</p> <p>b. ASET at least 2 times of RSET</p> |

**What are the deviations??**

Table 3: Details of Alternative Solutions at part(s) of the building affected by the performance-based solution.

| Part(s) of the building affected by performance-based solution | Relevant Prescriptive Clause and Alternative Solutions  | Relevant root and sub-objectives                          | Design solution  | Acceptance Criteria               |
|--|---|---|--|-----------------------------------|
| Car parks decks (2 <sup>nd</sup> to 6 <sup>th</sup> storey)    | <p>Clause 3.2.8(c)(i) – The requirements of Clause 3.2.1 may be exempted if open sided car parking decks having not less than 50% of the sides permanently open and unobstructed, and such openings being evenly distributed along each of the perimeter walls and on every individual floor/deck, excluding perimeter walls to air-well, so as to provide cross ventilation to all parts of the car parking decks;</p> <p>Clause 3.2.8(c)(ii) – No part of the floor space shall be more than 12m from the openings on the perimeter walls of the building or air-well. Air-well where provided for this purpose shall have a superficial plan area of not less than 10m<sup>2</sup>, or 0.1m<sup>2</sup> for every 300mm of height, whichever is greater, and have a minimum dimension on plan of 2000mm, open vertically to the sky for its full height.</p> | <p>Root objectives – R6.2</p> <p>Sub-objectives: S6.2</p> | <p>Automatic sprinkler system.</p> <p>Large openings along the car parks perimeters and two voids at the center.</p> | Refer to Section 10 of the report |

**What would be very helpful to highlight ??**

**What are the deviations ??**



## Alternative Solution

- 1<sup>st</sup> to 4<sup>th</sup> storey warehouses are divided into two smoke zones with the maximum smoke reservoir size of 5225 m<sup>2</sup> and length is approximately 112m.

- 5<sup>th</sup> and 6<sup>th</sup> storey warehouse storage is a single smoke zone of 6,500 m<sup>2</sup> and the length approximately is 112m.


## Standardise :

Comma / No-comma.

Helps with the word-search.



- Bad colour contrast.
- Bad choice of colours



FLOOR HEIGHT = 3100mm

**Performance-based Design - Increase OL @ 3rd storey**

Proposed OL - 1268  
 Exit capacity - 1260  
 Shortfall of 28


**Enhancement to the PBD**

Enhancement to existing exposed sprinklers with fast response sprinklers of a RTI value not more than  $50m^{1/2}s^{1/2}$  to the front of house of affected floor with increase occupant load, i.e. 3<sup>rd</sup> storey.

**Fire Scenarios**

- (1) Atrium fire -
  - (A) Base case
  - (B) Sensitivity with 20% increase in fire size
  - (C) One exit blocked
- (2) Shop fire -
  - (A) Base case
  - (B) Sensitivity with 20% increase in fire size
  - (C) One exit blocked

Existing compliance engineered control system to provide acceptable tenable condition along path of egress during a fire evacuation.



| Location   | Fire Scenario                                      | ASET                      | RSET  | ASET/RSET | Acceptance Criteria met? |
|--|--|---------------------------|-------|-----------|--------------------------|
| Fire @ atrium<br>(3 <sup>rd</sup> storey for worse scenario) | Base Case (1A)                                     | >1200 s<br>(steady state) | 401 s | > 2       | Yes                      |
|  | Sensitivity Case (1B) – Increase in fire size      | >1200 s<br>(steady state) | 401 s | > 1.2     | Yes                      |
|  | Sensitivity Case (1C) – One exit staircase blocked | >1200 s<br>(steady state) | 429 s | > 1.2     | Yes                      |
| Fire in 3 <sup>rd</sup> storey retail shop                   | Base Case (2A)                                     | >1200 s<br>(steady state) | 391 s | > 2       | Yes                      |
|  | Sensitivity Case (2B) – Increase in fire size      | >1200 s<br>(steady state) | 391 s | > 1.2     | Yes                      |
|  | Sensitivity Case (2C) – One exit staircase blocked | >1200 s<br>(steady state) | 419 s | > 1.2     | Yes                      |




FLOOR HEIGHT 3000MM TO 4100MM

Zones Sizes do not exceed 3000 sqm  
Main Exhaust Points located away from Exits  
Fire Scenario BC2

*“Staircases have  
been marked in  
red for easy  
location.”*


*Really ????*



LOWER 1ST STOREY PLAN



Zone 1 total area 3367sqm > 2000sqm.  
Split into 2 sprinkler sub-zones with individual flow switch.  
Zone 1A = 1,293sqm  
Zone 1B = 2,074sqm



Zone 3 total area 2000sqm.  
Split into 2 sprinkler sub-zones with individual flow switch.  
Zone 3A = 159sqm  
Zone 3B = 1841sqm

Zone 2 total area 3411sqm > 2000sqm.  
Split into 2 sprinkler sub-zones with individual flow switch.  
Zone 2A = 1246sqm  
Zone 2B = 2165sqm

**PB ISSUES**

1. JET FAN ZONES > 2,000m<sup>2</sup>
2. JET FAN SUCCESSIVE LAYOUT > 2/3 FAN TRAJECTORY APART

**TRIAL DESIGN**

01 x PASSENGER CAR ON FIRE 4MW (CONSTANT)  
02 x JET FANS ASSUMED FAILURE

Jet Fan max trajectory 41.5m  
2/3 fan trajectory is 27.1m  
Placement of successive fans at 32m or less apart. FSR3 allows for fans > 2/3 trajectory apart if CFD shows meeting of acceptance criteria.

**BASEMENT 1 PLAN - DUCTLESS CARPARK MECHANICAL VENTILATION SYSTEM**  
SYSTEM DESIGNED TO 9 AIR-CHANGES PER HOUR IN EMERGENCY MODE



255m > 60m

Omission of fire rated roller shutters.

Truck Fire Size 4MW < 10MW

Activation of ESCS by sprinkler flow switches.

146m > 60m

155m > 60m

Reservoir Size 28,050m<sup>2</sup> > 2,600m<sup>2</sup>

L1D1 - 4.0MW

219m > 60m


# Avoid legends

### LEGEND

-  DRIVEWAY (FB MECHANICAL ESCS)
-  FACTORY UNIT
-  SMOKE EXTRACTION DUCT
-  FLOW SWITCH ZONE
-  LOUVRE (MIN Cv=50%)
-  FULL HEIGHT WALL/PARTITION/FIRE RATED GLASS
-  PERFORATED ROLLER SHUTTER (MIN Cv=25%)

1ST STOREY PLAN (Height : 6.0m)


SCALE 1:500




Something critical is missing from these following three slides??  
[Don't let us guess/assume.]

## Radiant Heat Assessment – Scenario RS 1 @ 1MW Fire: CFD Simulation Slices

Plan View



View "A"



Bndry  
net  
kW/m<sup>2</sup>

2.50

2.25

2.00

1.75

1.50

1.25

1.00

0.75

0.50

0.25

0.00




View "A"

Scenario RS1: Typical fire  
involving rubbish bags or  
baggage @ 1MW

Radiant heat impact on the  
obstruction (occupants) is  
within acceptable range  
( $<2.5\text{kW/m}^2$ )

# Assessment – Tenable Conditions for Occupant Life Safety : Smoke Visibility & Gas Temperature:- CFD Simulation Slices


- Scenario S1 Visibility slice @  $z=2.5\text{m}$  above L1




# Assessment – Tenable Conditions for Occupant Life Safety : Smoke Visibility & Gas Temperature:- CFD Simulation Slices

- Scenario S1

Visibility slice @ Y-axis across fire



Visibility slice @ X-axis across fire



# **PB Administrative Requirements (Full PB? or Waiver with fire engineering? Or Letter of No Objection)**



## Full PB Framework:

1. Changes affecting original PB areas.
2. New PB deviations.
3. Same deviation in new areas.

### Example 1 :

FER approved with smoke reservoir 4,000 m<sup>2</sup>.

A/A works increases smoke reservoir to 6,000 m<sup>2</sup>.

### Example 2 :

FER approved with only smoke reservoir and travel distance issues.

Compartment issues discovered.

### Example 3 :

FER approved with travel distance on levels 1 and 2.

Travel distance issues discovered on level 3.



## Full PB Framework:

1. Changes affecting original PB areas.
2. New PB deviations.
3. Same deviation in new areas.

### Example 4 :

FER has approved NV system with full openings.

A/A works to add rain screen.



## Full PB Framework:

1. Changes affecting original PB areas.
2. New PB deviations.
3. Same deviation in new areas.

Formally submit **Amendment FEDB**, quoting original FEDB reference number.

Submission via :

- CORENET or
- SCDF Front counter

Example :

Previously approved : FEDB/000995/17

**Amendment** FEDB : FEDB/000995/17**01**, FEDB/000995/17**02**



## Full PB Framework:

1. Changes affecting original PB areas.
2. New PB deviations.
3. Same deviation in new areas.

## PB waiver allowed only:

1. For clauses in Circular (Dec 2015) and/or
2. If prescriptive WVR Decision specifies that WVR with additional fire engineering study is needed.

May still be directed to full PB in situations where :

- The relevant clause is in the Dec 2015 circular but there are other PB issues for the development. All fire engineering issues needs to be looked at holistically.
- Other fire engineering issues were not highlighted during the Prescriptive WVR application. All fire engineering issues needs to be looked at holistically.



# Submission of PB Waiver when it should be full PB

- *Rejection : Issues to be regularized under the full performance based framework as highlighted to FSE on 12/3/18.*



## Full PB Framework:

1. Changes affecting original PB areas.
2. New PB deviations.
3. Same deviation in new areas.

## PB waiver allowed only:

1. For clauses in Circular (Dec 2015) and/or
2. If prescriptive WVR Decision specifies that WVR with additional fire engineering study is needed.

## Letter of No Objection (Typically in another area) only if:

1. A & A works do not affect PB design at all:
  - a) FSE/QP to assess (See SCDF Circular dated 18 Oct 2013)
  - b) If unsure, FSE perform assessment and decide for yourself. FSE can issue LNO if:
    - Locations of A/A works are clearly in a non-PB related part of the building; or
    - A/A works give rise to the same (previously assessed) deviations in the PB area, but the performance-based results are obviously similar to earlier approved report, or performs better than results in the earlier approved report.
      - Example: Original PB involved travel distance non-compliance, and PB assessment is already approved. Subsequently, there are A&A works in the same PB area, and results in a shorter travel distance non-compliance.



# Any Other Business



**SCDF**  
The Life Saving Force



# Any other business :

1. Manage your clients/QP.
  - We rather spend the time reviewing your reports.
  - Remind your client/QP not to contact us directly, but liaise through the FSE, no matter how urgent the cases are.
  - Potential consequence: Project delay
2. Number all Table and Figures.
3. For all reports (FEDB/FER/O&M/PRR)
  - a) Every WVR/FEDB/FER/PRR must be self-sufficient. (Do not reference other reports for key details.)
  - b) FSE & Peer Reviewer to also insert email address on the cover page of all reports.
4. Bring your own VGA cables/adaptor for projection onto screen



## Any other business :

5. Avoid communicating via CORENET Correspondences ONLY.
6. Compile whole report into a single document if possible. Do not give us in 10 parts.
7. Total size of report not to exceed 20MB.
8. Indicate correct reference numbers (ie FEDB/0000XX/YY) when submitting BP drawings at FER stage. **Else REJECT**



## Any other business :

9. All reports are to be searchable.
10. Submit only the final results that shows trial design meets acceptance criteria.
11. “Discussion to be led by FSE”.
12. Consult only on PB issues.
13. Peer reviewer to differentiate (via **tabulation**) fire scenarios from FSE.
14. Revert to all queries within 3 months. **Else Disapprove/Rescind NOA**



# Q & A



**SCDF**  
The Life Saving Force



# Queries received from FSEs:

1. Use of Fractional Effective Dose (FED)
  - a. Is it through SCDF Consultation at the on-set of project, either for PB or wavier approach, to agree on the FED usage?
  - b. If it is, what details SCDF needs for the consultation?
  - c. Is the application of FED only applicable to new project or A&A works?

3.3 Where the fire engineering assessment requires an assessment of human tenability to be made, the following limits of acceptability will apply:




Figure 3.2 Tenability criteria to be sampled at 2.5m from the finish floor level.

- (a) Smoke Temperature – The average upper layer smoke temperature shall not exceed 200°C measured at 2.5m height from finished floor level and the average lower layer smoke temperature shall not exceed 60°C.
- (b) Radiation – Where occupants are expected to egress past a fire, the radiative heat flux shall not exceed 2.5 kW/m<sup>2</sup>.
- (c) Visibility at 2.5m above the floor level shall be greater than 10m.
- (d) Where the use of FED is to be used as an acceptance criterion, (for example, in situation where the ceiling is low and the use of acceptance criteria (a) to (c) is not feasible).

Fractional Effective Dose (FED) for temperature and toxic gases shall not exceed 0.3.

Acceptance Criteria

Temperature

Radiation

Visibility

Fractional Effective Dose

The use of FED as a criterion shall be subject to SCDF's agreement. When proposed, the FSE would need to justify for FED criterion to be adopted in the design. Where FED analysis is permitted by SCDF, the guide for the sampling shall be as follows

## (i) Methodology for FED determination

The recommended methodology for FED determination is proposed below. Depending on the nature of the deviation, FSE may propose other methodologies for determining FED. FSE would need to consult SCDF before embarking on the FEDB.

- (1) FED is sampled at the floor on fire and at all the entrances to places of safety (Eg: Doors to staircases/smoke stop lobby or doors to the external). These are areas where queuing is expected to take place.

Snap shots of egress modelling would need to be submitted to SCDF to show when queuing has reached the peak. This is to justify areas where FED sampling will be carried out.

- (2) Calculate or model the queuing domain and another 5 m away for the FED sampling.




Figure 3.3 - FED Sampling

Methodology for FED determination

**FSE-CPE = 3 hours**  
**for FSE Dialogue 2018 attendees**



**SCDF**  
The Life Saving Force



# Project Priority Card

for FSE Dialogue 2018 attendees



**SCDF**  
The Life Saving Force



- ✓ One for each FSE.
- ✓ Valid for one submission only (either FEDB or FER or PB-WVR).
- ✓ Non-transferable. Must be the submission FSE.
- ✓ Valid until next FSE dialogue.
- ✓ Non-Replaceable if you lose/damage it.
- ✓ Physically surrender to Nic/Tong before it can be used.
- ✓ Must be in good condition to us used.
- ✓ Allows priority for ONE
  - Review only; or
  - Presentation only
- ✓ Can be used to borrow VGA adaptor for consultation.



# End



**SCDF**  
The Life Saving Force

